



May 26, 2010

DEPARTMENT OF COMMERCE
SAFETY AND BUILDINGS
KEN PERTZBORN
201 W WASHINGTON AVE
PO BOX 7162
MADISON WI 53707-7162

Re: Description: SIZING OF DRAIN PIPING SERVING REFRIGERATED FOOD DISPLAY CASES, ALT.
PLBG. SYSTEM
Manufacturer: DEPARTMENT OF COMMERCE
Product Name: DFU ASSIGNMENT TO RECEPTORS OF INDIRECT WASTE, AND DRAIN SYSTEM(S)
Model Number(s): NONE
Product File No: 20100244

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.30 (3)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This approval applies to receptors that only receive discharge from refrigerated food display cases.
- The trap size for receptors of indirect waste serving refrigerated food display cases under this alternate system shall be 2 to 4 inches.
- The drainage fixture unit value assigned to each receptor of indirect waste serving refrigerated food display cases is two.

This approval supersedes the approval issued on November 2, 2005 under product file number 20050818.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050818.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov